



ANNA FIRE PREVENTION DIVISION

305 S. Powell Pkwy.

Anna, Texas 75409

OFFICE 972-924-2143 ▪ FAX 972-924-2772

Mobile Food Unit

This inspection checklist is provided as a courtesy to assist with your kitchen hood suppression installation requirements

Project Name: _____

Permit #: _____

Address: _____

Date: _____

City, State, Zip: _____

Phone Number: _____

Email: _____

Y N N/A Appliances

- | | | | |
|--------------------------|--------------------------|--------------------------|--|
| <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | Are the appliances within the perimeter of the hood a minimum of 6 inches? |
| <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | Are deep fat fryers a minimum of 16" away from an open flame or have an 8" steel or tempered glass baffle installed? |
| <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | Are the fuel fired appliances compliant? |
| <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | Are the electrical appliances compliant? |

Y N N/A Hood Suppression System

- | | | | |
|--------------------------|--------------------------|--------------------------|---|
| <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | Does the vent hood suppression system have a current certification tag? |
|--------------------------|--------------------------|--------------------------|---|

Y N N/A Compressed Gas Cylinders

- | | | | |
|--------------------------|--------------------------|--------------------------|--|
| <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | Do gas cylinders have a current DOT certification? |
| <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | Are cylinders properly stored and secured? <ul style="list-style-type: none">▪ Minimum of 10-foot clearance from any trash or combustible material▪ Not kept in passenger area of vehicle |
| <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | Are cylinders protected from physical damage? |
| <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | Are cylinders, fittings, hoses and/or piping free of physical damage? |

Y N N/A Generator

- | | | | |
|--------------------------|--------------------------|--------------------------|---|
| <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | Is the generator compliant? |
| <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | Are fuels and/or electrical wiring compliant? |

Y N N/A Fire Extinguishers

- | | | | |
|--------------------------|--------------------------|--------------------------|---|
| <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | Is a "K" Class extinguisher present and have current certification tag? |
| <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | Do all extinguishers have current certification tags? (minimum 2A10BC) |
| <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | Are all extinguishers mounted properly? |
| <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | Are all extinguisher brackets free of damage? |

Y N N/A Electrical Systems

- | | | | |
|--------------------------|--------------------------|--------------------------|---|
| <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | Are electrical systems compliant? |
| <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | Are approved extension cords present? |
| <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | Are approved multi-plug adaptors present? |

Comments: _____

Inspector's Name: _____ Contractor's Name & License #: _____