

Anna Water Quality Report for the period of January 1, 2017 to December 31, 2017

This report is intended to provide you with important information about your drinking water and the efforts made by the water system to provide safe drinking water.

An Annual Insight into Drinking Water Quality

About this Report

The City of Anna is pleased to share this water quality report with you. It describes to you, our customer, the quality of your drinking water.

The City of Anna meets or exceeds Texas Commission on Environmental Quality (TCEQ) and United States Environmental Protection Agency (US EPA) regulations for drinking water.

Lead and Copper

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We are responsible for providing high quality drinking water, but we cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

PWS ID Number: TX0430027

**En Español Este reporte incluye información importante sobre el agua para tomar.
Para asistencia en español, favor de llamar al telefono (972) 924-4510**

Sources of Drinking Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPAs Safe Drinking Water Hotline at (800) 426-4791.

The City of Anna gets its water from a combination of ground (approximately 60%) and surface (approximately 40%) water sources. The ground water comes from seven deep water wells owned and operated by the City of Anna. The treated surface water is purchased from Greater Texoma Utility Authority (GTUA) through a joint agreement with North Texas Municipal Water District (NTMWD). The NTMWD relies on surface water from Lavon Lake, Lake Texoma, Lake Tawakoni and Jim Chapman Lake (Cooper Lake). Your water is treated through sedimentation, filtration, and disinfection to reduce or remove harmful contaminants that may be present in your drinking water.

Contaminants

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.
- Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Contaminants may be found in drinking water that may cause taste, color, or odor problems. These types of problems are not necessarily causes for health concerns. For more information on taste, odor, or color of drinking water, please contact Troy Hopkins at (972) 924-4510.

Information about Source Water Assessments

The TCEQ completed an assessment of your source water and results indicate that some of your sources are susceptible to certain contaminants. The sampling requirements for your water system are based on this susceptibility and previous sample data. Any detections of these contaminants may be found in this Consumer Confidence Report. For more information on source water assessments and protection efforts at our system, contact Troy Hopkins at (972) 924-4510.

For more information about your sources of water, please refer to the Source Water Assessment Viewer available at the following URL: <http://www.tceq.texas.gov/gis/swaview>
For further details about sources and source-water assessments are available in Drinking Water Watch at the following URL: <http://dww2.tceq.texas.gov/DWW/>

Special Notice



You may be more vulnerable than the general population to certain microbial contaminants, such as *Cryptosporidium*, in drinking water. Infants, some elderly, or immunocompromised persons such as those undergoing chemotherapy for cancer; persons who have undergone organ transplants; those who are undergoing treatment with steroids; and people with HIV/AIDS or other immune system disorders, can be particularly at risk from infections. You should seek advice about drinking water from your physician or health care providers. Additional guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* are available from the Safe Drinking Water Hotline (800-426-4791).

Public Participation

City Council Meetings

Location:
City Hall Administration Building
111 N. Powell Parkway
Anna, Texas 75409

Date:
Second and fourth Tuesday of each month.

Time:
7:30 PM

**For more information regarding this report contact: Troy Hopkins,
Water Superintendent at (972) 924-4510**

Regulated Contaminants Detected - Groundwater Sources; City of Anna

Lead and Copper

Definitions:

Action Level Goal (ALG): The level of a contaminant in drinking water below which there is no known or expected risk to health. ALGs allow for a margin of safety.

Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Lead and Copper	Date Sampled	MCLG	Action Level (AL)	90th Percentile	# Sites Over AL	Units	Violation (Y/N)	Likely Source of Contamination
Copper	9/29/17	1.3	1.3	0.18	0	ppm	N	Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing systems.
Lead	9/29/17	0	15	2.0	0	ppb	N	Corrosion of household plumbing systems; Erosion of natural deposits.

Water Quality Test Results — Regulated Contaminants

Disinfectants and Disinfection By-Products	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation (Y/N)	Likely Source of Contamination
Haloacetic Acids (HAA5)*	2017	31.3	31.3 - 31.3	No goal for the total	60	ppb	N	By-product of drinking water disinfection.
Total Trihalomethanes (TTHM)	2017	21	21 - 21	No goal for the total	80	ppb	N	By-product of drinking water disinfection.

Inorganic Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation (Y/N)	Likely Source of Contamination
Barium	6/29/15	0.053	0.0038 - 0.036	2	2	ppm	N	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.
Chromium	6/29/15	3	0 - 3	100	100	ppb	N	Discharge from steel and pulp mills; Erosion of natural deposits.
Fluoride	6/29/15	2.04	0.484 - 2.04	4	4.0	ppm	N	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories.
Nitrate [measured as Nitrogen]	2017	0.574	.044— .574	10	10	ppm	N	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits.

NITRATE ADVISORY: Nitrate in drinking water at levels above 10 ppm is a health risk for infants of less than six months of age. High nitrate levels in drinking water can cause blue baby syndrome. Nitrate levels may rise quickly for short periods of time because of rainfall or agricultural activity. If you are caring for an infant you should ask advice from your healthcare provider.

Radioactive Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation (Y/N)	Likely Source of Contamination
Beta/photon emitters	6/29/15	4.1	0 - 4.1	0	50	pCi/L*	N	Decay of natural and man-made deposits. *EPA considers 50 pCi/L to be the level of concern for beta particles.
Combined Radium 226/228	6/29/15	1.5	1.5 - 1.5	0	5	pCi/L	N	Erosion of natural deposits.

*EPA considers 50 pCi/L to be the level of concern for beta particles.

Disinfectant Residual Table

Disinfectant Method Used	Collection Date	Average Level	Minimum Level	Maximum Level	MRDL	MRDLG	Unit of Measure	Violation (Y/N)	Chemical Source
Free Chlorine Residual (Pure chlorine gas)	2017	1.20	0.20	6.2	4.0	4.0	ppm	N	Water additive used to control microbes.

The system is in compliance with the maximum residual disinfectant level if the running annual average of all samples taken in the distribution system is less than 4.0 mg/l. The system is in compliance with the minimum residual disinfectant level if less than 5% of the monthly samples were under the minimum level.

Definitions

The adjacent tables contain scientific terms and measures, some of which may require explanation.

Avg: Regulatory compliance with some MCLs are based on running annual average of monthly samples.

Maximum Contaminant Level or MCL: The highest level of a contaminant that is allowed in drinking water.

MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Level 1 Assessment: A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Maximum Contaminant Level Goal or MCLG: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum residual disinfectant level or MRDL: The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum residual disinfectant level goal or MRDLG: The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

MFL: million fibers per liter (a measure of asbestos)

mrem: millirems per year (a measure of radiation absorbed by the body)

na: not applicable.

NTU: nephelometric turbidity units (a measure of turbidity)

pCi/L: picocuries per liter (a measure of radioactivity)

ppb: micrograms per liter or parts per billion - or one ounce in 7,350,000 gallons of water.

ppm: milligrams per liter or parts per million - or one ounce in 7,350 gallons of water.

ppt: parts per trillion, or nanograms per liter (ng/L)

ppq: parts per quadrillion, or picograms per liter (pg/L)

Treatment Technique or TT: A required process intended to reduce the level of a contaminant in drinking water.



Visit: www.annatexas.gov

Regulated Contaminants								
Disinfectants and Disinfection By-Products	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Bromate	2017	Levels lower than detect level	0.0 - 0.00	5	10	ppb	No	By-product of drinking water ozonation.
NOTE: Not all sample results may have been used for calculating the Highest Level Detected because some results may be part of an evaluation to determine where compliance sampling should occur in the future.								
Inorganic Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Antimony	2017	Levels lower than detect level	0-0	6	6	ppb	No	Discharge from petroleum refineries; fire retardants; ceramics; electronics; solder; and test addition.
Arsenic	2017	Levels lower than detect level	0.0-0.0	0	10	ppb	No	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes.
Barium	2017	0.060	0.059— 0.060	2	2	ppm	No	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits.
Beryllium	2017	Levels lower than detect level	0 - 0	4	4	ppb	No	Discharge from metal refineries and coal-burning factories; discharge from electrical, aerospace, and defense industries.
Cadmium	2017	Levels lower than detect level	0 - 0	5	5	ppb	No	Corrosion of galvanized pipes; erosion of natural deposits; discharge from metal refineries; runoff from waste batteries and paints.
Chromium	2017	Levels lower than detect level	0.52 - 1.20	100	100	ppb	No	Discharge from steel and pulp mills; erosion of natural deposits.
Fluoride	2017	0.38	0.26 - 0.38	4	4	ppm	No	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories.
Mercury	2017	Levels lower than detect level	0 - 0	2	2	ppb	No	Erosion of natural deposits; discharge from refineries and factories; runoff from landfills; runoff from cropland.
Nitrate (measured as Nitrogen)	2017	0.97	0.09 - 0.97	10	10	ppm	No	Runoff from fertilizer use; leaching from septic tanks; sewage; erosion of natural deposits.
Selenium	2017	Levels lower than detect level	1.4 - 3.4	50	50	ppb	No	Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines.
Thallium	2017	Levels lower than detect level	0 - 0	0.5	2	ppb	No	Discharge from electronics, glass, and leaching from ore-processing sites; drug factories.
NITRATE ADVISORY: Nitrate in drinking water at levels above 10 ppm is a health risk for infants of less than six months of age. High nitrate levels in drinking water can cause blue baby syndrome. Nitrate levels may rise quickly for short periods of time because of rainfall or agricultural activity. If you are caring for an infant you should ask advice from your healthcare provider.								
Radioactive Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Beta/photon emitters	2017	6.2	6.2 - 6.2	0	50	pCi/L*	No	Decay of natural and man-made deposits.
Gross alpha excluding radon and uranium	2017	Levels lower than detect level	0 - 0	0	15	pCi/L	No	Erosion of natural deposits.
Radium	2017	1.27	1.27—1.27	0	5	pCi/L	No	Erosion of natural deposits.

*EPA considers 50 pCi/L to be the level of concern for beta particles.

Regulated Contaminants — Surface Water Source; North Texas Municipal Water District

Synthetic organic contaminants including pesticides and herbicides	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
2, 4, 5 - TP (Silvex)	2017	Levels lower than detect level	0 - 0	50	50	ppb	No	Residue of banned herbicide.
2, 4 - D	2017	Levels lower than detect level	0 - 0	70	70	ppb	No	Runoff from herbicide used on row crops.
Alachlor	2017	Levels lower than detect level	0 - 0	0	2	ppb	No	Runoff from herbicide used on row crops.
Atrazine	2017	0.20	0.20 - 0.20	3	3	ppb	No	Runoff from herbicide used on row crops.
Benzo (a) pyrene	2017	Levels lower than detect level	0 - 0	0	200	ppt	No	Leaching from linings of water storage tanks and distribution lines.
Carbofuran	2017	Levels lower than detect level	0 - 0	40	40	ppb	No	Leaching of soil fumigant used on rice and alfalfa.
Chlordane	2017	Levels lower than detect level	0 - 0	0	2	ppb	No	Residue of banned termiticide.
Dalapon	2017	Levels lower than detect level	0 - 0	200	200	ppb	No	Runoff from herbicide used on rights of way.
Di (2-ethylhexyl) adipate	2017	Levels lower than detect level	0 - 0	400	400	ppb	No	Discharge from chemical factories.
Di (2-ethylhexyl) phthalate	2017	Levels lower than detect level	0.0 - 0.0	0	6	ppb	No	Discharge from rubber and chemical factories.
Dibromochloropropane (DBCP)	2017	Levels lower than detect level	0 - 0	0	0	ppt	No	Runoff / leaching from soil fumigant used on soybeans, cotton, pineapples, and orchards.
Dinoseb	2017	Levels lower than detect level	0 - 0	7	7	ppb	No	Runoff from herbicide used on soybeans and vegetables.
Endrin	2017	Levels lower than detect level	0 - 0	2	2	ppb	No	Residue of banned insecticide.
Ethylene dibromide	2017	Levels lower than detect level	0 - 0	0	50	ppt	No	Discharge from petroleum refineries.
Heptachlor	2017	Levels lower than detect level	0 - 0	0	400	ppt	No	Residue of banned termiticide.
Heptachlor epoxide	2017	Levels lower than detect level	0 - 0	0	200	ppt	No	Breakdown of heptachlor.
Hexachlorobenzene	2017	Levels lower than detect level	0 - 0	0	1	ppb	No	Discharge from metal refineries and agricultural chemical factories.
Hexachlorocyclopentadiene	2017	Levels lower than detect level	0 - 0	50	50	ppb	No	Discharge from chemical factories.
Lindane	2017	Levels lower than detect level	0 - 0	200	200	ppt	No	Runoff / leaching from insecticide used on cattle, lumber, and gardens.
Methoxychlor	2017	Levels lower than detect level	0 - 0	40	40	ppb	No	Runoff / leaching from insecticide used on fruits, vegetables, alfalfa, and livestock.
Oxamyl [Vydate]	2017	Levels lower than detect level	0 - 0	200	200	ppb	No	Runoff / leaching from insecticide used on apples, potatoes, and tomatoes.
Pentachlorophenol	2017	Levels lower than detect level	0 - 0	0	1	ppb	No	Discharge from wood preserving factories.
Simazine	2017	Levels lower than detect level	0 - 0	4	4	ppb	No	Herbicide runoff.
Toxaphene	2017	Levels lower than detect level	0 - 0	0	3	ppb	No	Runoff / leaching from insecticide used on cotton and cattle.

Regulated Contaminants — Surface Water Source; North Texas Municipal Water District

Volatile Organic Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
1, 1, 1 - Trichloroethane	2017	Levels lower than detect level	0 - 0	200	200	ppb	No	Discharge from metal degreasing sites and other factories.
1, 1, 2 - Trichloroethane	2017	Levels lower than detect level	0 - 0	3	5	ppb	No	Discharge from industrial chemical factories.
1, 1 - Dichloroethylene	2017	Levels lower than detect level	0 - 0	7	7	ppb	No	Discharge from industrial chemical factories.
1, 2, 4 - Trichlorobenzene	2017	Levels lower than detect level	0 - 0	70	70	ppb	No	Discharge from textile-finishing factories.
1, 2 - Dichloroethane	2017	Levels lower than detect level	0 - 0	0	5	ppb	No	Discharge from industrial chemical factories.
1, 2 - Dichloropropane	2017	Levels lower than detect level	0 - 0	0	5	ppb	No	Discharge from industrial chemical factories.
Benzene	2017	Levels lower than detect level	0 - 0	0	5	ppb	No	Discharge from factories; leaching from gas storage tanks and landfills.
Carbon Tetrachloride	2017	Levels lower than detect level	0 - 0	0	5	ppb	No	Discharge from chemical plants and other industrial activities.
Chlorobenzene	2017	Levels lower than detect level	0 - 0	100	100	ppb	No	Discharge from chemical and agricultural chemical factories.
Dichloromethane	2017	Levels lower than detect level	0 - 0	0	5	ppb	No	Discharge from pharmaceutical and chemical factories.
Ethylbenzene	2017	Levels lower than detect level	0 - 0	0	700	ppb	No	Discharge from petroleum refineries.
Styrene	2017	Levels lower than detect level	0 - 0	100	100	ppb	No	Discharge from rubber and plastic factories; leaching from landfills.
Tetrachloroethylene	2017	Levels lower than detect level	0 - 0	0	5	ppb	No	Discharge from factories and dry cleaners.
Toluene	2017	Levels lower than detect level	0 - 0	1	1	ppm	No	Discharge from petroleum factories.
Trichloroethylene	2017	Levels lower than detect level	0 - 0	0	5	ppb	No	Discharge from metal degreasing sites and other factories.
Vinyl Chloride	2017	Levels lower than detect level	0 - 0	0	2	ppb	No	Leaching from PVC piping; discharge from plastics factories.
Xylenes	2017	Levels lower than detect level	0 - 0	10	10	ppm	No	Discharge from petroleum factories; discharge from chemical factories.
cis - 1, 2 - Dichloroethene	2017	Levels lower than detect level	0 - 0	70	70	ppb	No	Discharge from industrial chemical factories.
o - Dichlorobenzene	2017	Levels lower than detect level	0 - 0	600	600	ppb	No	Discharge from industrial chemical factories.
p - Dichlorobenzene	2017	Levels lower than detect level	0 - 0	75	75	ppb	No	Discharge from industrial chemical factories.
trans - 1, 2 - Dichloroethylene	2017	Levels lower than detect level	0 - 0	100	100	ppb	No	Discharge from industrial chemical factories.

Turbidity Note: Turbidity is a measurement of the cloudiness of the water caused by suspended particles. We monitor it because it is a good indicator of water quality and the effectiveness of our filtration.

Type	Limit (Treatment Technique)	Level Detected	Violation	Likely Source of Contamination
Highest Single Measurement	1 NTU	0.74 NTU	No	Soil runoff.
Lowest monthly percentage (%) meeting limit	0.3 NTU	99.30%	No	Soil runoff.

Total Organic Carbon Note: Total organic carbon (TOC) has no health effects. The disinfectant can combine with TOC to form disinfection by-products. Disinfection is necessary to ensure that water does not have unacceptable levels of pathogens. By-products of disinfection include trihalomethanes (THMs) and haloacetic acids (HAA) which are reported elsewhere in this report.* Removal ratio is the percent of TOC removed by the treatment process divided by the percent of TOC required by TCEQ to be removed.

Collection Date	Highest Level Detected	Range of Levels Detected	Unit	Likely Source of Contamination	
Source Water	2017	4.38	3.93 - 4.38	ppm	Naturally present in the environment.
Drinking Water	2017	3.24	2.20 - 3.24	ppm	Naturally present in the environment.
Removal Ratio	2017	47.2%	22.5 - 47.2	% removal*	N/A

Cryptosporidium

Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	Unit	Likely Source of Contamination
Cryptosporidium	2017	0	0 - 0	(Oo) Cysts/L	Human and animal fecal waste.
Giardia	2017	0	0 - 0	(Oo) Cysts/L	Human and animal fecal waste

Total Trihalomethanes (TTHMs)

Some people who drink water containing trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous systems, and may have an increased risk of getting cancer.

As noted in this report, total trihalomethanes sampling within our system indicated that levels were well below the MCL.



Total and Fecal Coliform

Reported monthly samples found no total or fecal coliform.

Source: Naturally occurring in the environment.

Coliform Bacteria

Maximum Contaminant Level Goal	Total Coliform Maximum Contaminant Level	Highest No. of Positive	Fecal Coliform or E. Coli Maximum Contaminant Level	Total No. of Positive E. Coli or Fecal Coliform Samples	Violation	Likely Source of Contamination
0	1 positive monthly sample.	0	0	0	N	Naturally present in the environment.

Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially harmful, waterborne pathogens may be present or that a potential pathway exists through which contamination may enter the drinking water distribution system. We found coliforms indicating the need to look for potential problems in water treatment or distribution. When this occurs, we are required to conduct an assessment to identify problems and to correct any problems that were found during the assessment.

Violations Table

Lead and Copper Rule

The lead and Copper Rule protects public health by minimizing lead and copper levels in drinking water, primarily by reducing water corrosivity. Lead and copper enter drinking water mainly from corrosion of lead and copper containing plumbing materials.

Violation Type	Violation Begin	Violation End	Violation Explanation
FOLLOW-UP OR ROUTINE TAP M/R (LCR)	10/1/2017	2017	We failed to test our drinking water for the contaminant and period indicated. Because of this failure, we cannot be sure of the quality of our drinking water during this period.

The city of Anna collected the 30 samples that were required by the Texas Commission on Environmental Quality (TCEQ). However, two samples were collected from sampling sites that were not on the pre-approved list from the original Lead and Copper testing sites. All of the samples that were collected and analyzed were below the Maximum Contaminant Level for Lead or Copper.

Revised Total Coliform Rule (RTCR)

The Revised Total Coliform Rule (RTCR) seeks to prevent waterborne diseases caused by E. coli. E. Coli are bacteria whose presence indicates that the water may be contaminated with human or animal wastes. Human pathogens in these wastes can cause short-term effects, such as diarrhea, cramps, nausea, headaches or other symptoms. They may pose a greater health risk for infants, young children, the elderly, and people with severely compromised immune systems.

Violation Type	Violation Begin	Violation End	Violation Explanation
MONITORING, ROUTINE, MAJOR (RTCR)	04/1/2017	04/30/2017	We failed to test our drinking water for the contaminant and period indicated. Because of this failure, we cannot be sure of the quality of our drinking water during the period indicated.

The City of Anna collected all of the required samples and submitted them to the TCEQ approved lab. In April, the lab did not report the results in the required amount of time which resulted in a violation. Once the lab reported the samples, the violation was resolved.

Water Conservation

The City of Anna encourages the responsible use of our water resources. Please visit our website for information on water conservation. You can get there by going to www.annatexas.gov and clicking "Water Conservation".

Watering Restrictions

City of Anna landscape watering is currently limited to two days per week. There are no assigned watering days. Please visit our website and click "Water Conservation" for more information.

Water Loss

In the water loss audit submitted to the Texas Water Development Board for the time period of Jan-Dec 2017, our system lost an estimated 28,116,498 gallons of water. If you have any questions about the water loss audit please call (972) 924-4510.

Thank You

The Public Works Department is dedicated to providing a safe and uninterrupted source of drinking water to our citizens. Water quality is important to us. Please do not hesitate to contact us at (972) 924-4510 if you have any questions or concerns.

Visit: www.annatexas.gov

THE CITY OF
Anna

